



Office of the Administrative Director – Financial Services Department

THE JUDICIARY • STATE OF HAWAII • 1111 ALAKEA STREET, 6TH FLOOR • HONOLULU, HAWAII 96813-2807
TELEPHONE (808) 538-5800 • FAX (808) 538-5802

Rodney A. Maile
ADMINISTRATIVE DIRECTOR

Dean H. Seki
FINANCIAL SERVICES DIRECTOR

Iris T. Murayama
DEPUTY ADMINISTRATIVE DIRECTOR

May 6, 2016

MEMORANDUM

TO WHOM IT MAY CONCERN:

FROM: Dean H. Seki, Financial Services Director

SUBJECT: ADDENDUM NO. 2
JUDICIARY PROJECT NO. J16303
KAUIKEAOULI HALE UPGRADES
TO THE SECURITY CAMERA SYSTEM AND RELATED WORK
PROJECT IDENTIFIER: JUD 1516-01-DC01
TAX MAP KEY: 2-1-17:003
HONOLULU, OAHU, HAWAII

Transmitted herewith is a copy of Addendum No. 2, providing answers to questions that were posed.

Should you have any technical questions regarding this Addendum, please call the Officer-In-Charge for this project Dee Dee Letts, Office of Project Management, Ph. (808)538-5991 or deedee.d.letts@courts.hawaii.gov. Other questions may be directed to Jonathan Wong of the Judiciary Contracts & Purchasing Office at (808)538-5805, or jonathan.h.wong@courts.hawaii.gov

/s/ Dean H. Seki

Enc.: Kauikeaouli Security Camera - Q & A

ADDENDUM NO. 2
JUDICIARY PROJECT NO. J16303

TO THE PLANS AND SPECIFICATIONS
FOR THE
KAUIKEAOULI HALE UPGRADES TO
THE SECURITY CAMERA SYSTEM AND
RELATED WORK
THE JUDICARY, STATE OF
HAWAII,
1111 ALAKEA STREET
HONOLULU, OAHU, HAWAII
96813

TAX MAP KEY: 2-1-17: 003

The items listed hereinafter are hereby made a part of the contract for the above project and shall govern the work, taking precedence over previously issued plans and specifications governing the items mentioned:

1. QUESTIONS AND ANSWERS TO PROJECT J16303

Q-1. "Since we were unable to gain access into ITSD/ITCD datacenter could a distance from the nearest available breaker panel to proposed rack location be provided? This information will be used to determine a cost for an electrician to wire from rack to breaker panel."

A-1. The distance from the breaker panel being provided to the location of the proposed rack will be no more than 60 feet.

Q-2. "With reference to the cell cameras are these devices to be installed before/after working hours or can they be installed during business hours?"

A-2. Cameras located in the holding cells must be installed after normal business hours. Contractor must arrange for sheriff during the hours that this work is being performed. See **Specification Section 01100 (Project Requirements), Part 1 – General, section 1.05, Item E** for specifics.

Q-3. "In referencing the Exacq recorder, Specification Section 16800 (Sound and Video), Part 2 – Products, section 2.02, Item D, there are several variations of optional equipment that can be added to ensure proper operation and adequate resources are available.

Question is as follows: should the NVR's be quoted to include such options such as additional dual Gb NIC cards for data load balancing, and, should the NVR's be quoted to include the upgraded CPUs which would allow for additional resource availability?"

A-3. **Yes**, the NVR's should be quoted to include options such as additional dual Gb NIC cards for data load balancing.

Yes, the NVR's should be quoted to include the upgraded CPUs.

Q-4. "Since the site walk yesterday and after reviewing the site plans I had noticed that the sheriff personnel have access to the existing analog cameras in the cell block area. Question is as follows: will an additional client workstation need to be provided in the cell block area? If yes, which cameras will they have access to? How many monitors will be needed?"

A-4. **Yes**, the cell block needs to monitor all cell block/Sally Port cameras. An additional client workstation will be needed and 2 additional 40" monitors will also be needed. See **Specification Section 16800 (Sound and Video), Part 2 – Products, section 2.02, Items E and F** for workstation and monitor requirements.

- END OF ADDENDUM NO. 2 -