



**Office of the Administrative Director – Financial Services Department**

THE JUDICIARY • STATE OF HAWAII • 1111 ALAKEA STREET, 6<sup>TH</sup> FLOOR • HONOLULU, HAWAII 96813-2807  
TELEPHONE (808) 538-5800 • FAX (808) 538-5802

**Terri Gearon**  
FINANCIAL SERVICES DIRECTOR

June 7, 2019

MEMORANDUM

TO WHOM IT MAY CONCERN

FROM: Terri Gearon /s/ Terri Gearon  
Financial Services Director

SUBJECT: ADDENDUM NO. 2  
INVITATION FOR BID J19340  
2<sup>ND</sup> FLOOR TRANSACTION COUNTER IMPROVEMENTS  
KAUIKEAUOLI HALE, DISTRICT COURT OF THE 1<sup>ST</sup> CIRCUIT  
PROJECT IDENTIFIER: OMB 19-05-A

Transmitted herewith is a copy of Addendum No. 2 providing responses to questions submitted to IFB J19340.

Should you have any technical questions regarding this Addendum, please call the Officer-In-Charge for this project Ms. Dee Dee Letts at 808.538.5991 or [DeeDee.D.Letts@courts.hawaii.gov](mailto:DeeDee.D.Letts@courts.hawaii.gov). Other questions may be directed Ms. Tritia Cruz of the Judiciary Contracts & Purchasing Office at 808.538.5805 or [Tritia.L.Cruz@courts.hawaii.gov](mailto:Tritia.L.Cruz@courts.hawaii.gov).

Terri Gearon  
Financial Services Director

**THE JUDICIARY, STATE OF HAWAII**  
**IFB J19340**  
**KAUIKEAUOLI HALE**  
**2<sup>ND</sup> FLOOR COUNTER IMPROVEMENTS**

**QUESTIONS AND ANSWERS**

**Question #1:**

**“Do we need to have both a “B” and a “C-22” license to bid on this project?**

**Answer:**

**No, you do not have to have both a “B” and a “C-22” license to bid on this project. The “Requirements and Specifications,” Section 00110, Notice to Bidders, page 3 should have read “To be eligible to submit a Bid, the bidder must possess valid State of Hawaii Contractor’s license classification “B” and/or “C-22”**


**A “C-22” license is the only license required for this project. A “B” license holder can bid on this project as long as they possess a “C-22” sub license or list a subcontractor possessing this license and comply with the requirements of the “Requirements and Specifications”, Section 00210 Instructions to Bidders, Sub-section 1.05 – F, paragraphs 1 – 6.**

**Question #2:**

**What are the details for the mauka end of the counter by the pass through door?**

**Answer:**

**Please refer to the new, attached counter detail drawing entitled “KAUIKEAUOLI HALE SECOND FLOOR TRANSACTION COUNTERS Left End Bracket Elevation“ . Briefly stated, 1” x 3” Aluminum End piece extends below Glazing Channels as indicated and is attached securely to existing solid partition to match condition with Glazing Channels at each side of Teller Windows. At concrete columns 1” x 3” Aluminum Channel can be attached through hard rubber gaskets directly into column. Submit Shop Drawings as specified.**



Detail A-2 Kauikaeuoli Hale - Transaction Windows  
Section Details

Left End Bracket Elevation

Detail - Kauikaeuoli Hale - Blackout Roller Shades

KAUIKEAUOLI HALE SECOND FLOOR TRANSACTION WINDOWS

at  
Transaction Windows